

## 6.6 SPECIAL POLICIES

### 1) TURBINE FUEL FILTRATION POLICY - (Metropolitan NY Area Airports Only)

BUCKEYE PIPE LINE COMPANY, L.P.  
POLICY ON QUALITY STANDARDS, SAMPLING, TESTING  
AND ADDITIONAL CHARGES  
FOR  
AVIATION TURBINE FUEL TENDERED FOR DELIVERY  
TO THE METROPOLITAN NEW YORK CITY AIRPORTS  
EFFECTIVE JANUARY 1, 1986

#### A. Quality Standards

1. Aviation turbine fuel tendered for shipment under this tariff shall be deemed to be in compliance with quality standards when testing of samples taken at the origin point indicates the product meets all of the following criteria:
  - a. Undissolved water content equal to or less than 30 parts per million (P.P.M.) (ASTM 3240),
  - b. Filter membrane color rating equal to or less than 4 (ASTM D2276 except sample size shall be 3 gallons and the membrane shall be rated dry),
  - c. Surfactant content equivalent to a MSEP rating equal to or greater than 85 (ASTM D7224 or D3948).
2. These are current standards, and Buckeye reserves the right to modify any or all of the criteria as warranted by changes in quality requirements at the delivery points.

#### B. Sampling Locations

1. Samples will be taken as near the point of custody transfer at tariff origins as practical.
2. Samples will be taken from the head, middle and tail of each batch.

#### C. Product Testing

1. All sampling and testing activities will be performed by Buckeye personnel utilizing Buckeye owned equipment.
2. Filter membrane color rating shall be determined in accordance with the requirements of A.S.T.M. Standard Practice D2276. Sample size shall be 3 gallons and the membrane shall be rated dry. Color ratings which fall between two shades on the comparative chart shall be reported as the lighter of the two shades (lower number).
3. Undissolved water content shall be determined in accordance with the requirements of A.S.T.M. Standard Method D3240. A dynamic line sample shall be obtained through the same line connection utilized for filter membrane testing.

4. Surfactant content shall be measured by MSEP rating in accordance with the requirements of A.S.T.M. Standard Method D7224 or D3948. The sample to be tested shall be drawn into a clean, one gallon, epoxy lined metal can. When recording test results, the numerical rating shall be preceded by the letters MSEP.

*D. Additional Charges*

1. Additional charges for failure to meet quality standards shall be assessed as called for in the current Buckeye Pipe Line Company, L.P. tariff for Aviation Turbine Fuel Service to the metropolitan New York City airports.
2. The additional charges described herein shall be levied against the shipper of record at the point of custody transfer to Buckeye.